

Appendix I

Recommended Classification of FSIC

(I) Class 1 FSIC

Registered contractors who are responsible for handling electricity related FSI and are further subdivided into Class 1(a) and Class 1(b) :

(A) Class 1(a) FSIC

Registered contractors who are fit to install, maintain, repair and inspect any fire service installation or equipment (other than portable equipment) which contains an electric circuit or other apparatus for the detection and warning, by alarm or otherwise, of smoke or fire.

(B) Class 1(b) FSIC

Registered contractors who are fit to install, maintain, repair and inspect any fire service installation or equipment (other than portable equipment) which contains any type of electrical apparatus other than those specified in Class 1(a), (2) and (4) {i.e. emergency generator, emergency lighting, exit sign, audio/visual advisory system, etc.}.

(II) Class 2 FSIC

Registered contractors who are fit to install, maintain, repair and inspect any fire service installation or equipment (other than portable equipment) which contains pipes and fittings designed or adapted to carry water or some other fire extinguishing medium and any related electrical work/installation of these systems.

(III) Class 3 FSIC

Registered contractors who are fit to maintain, repair and inspect portable equipment.

(IV) Class 4 FSIC

Registered contractors who are fit to install, maintain, repair and inspect any fire service installation or equipment (other than portable equipment) which contains smoke management and control systems (i.e.

I

pressurization of staircase/smoke extraction/VAC control system) and any related electrical work of these systems.